

General Health Information

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Results of radon monitoring

Radon is a radioactive gas that you can't see, taste, or smell. It is found throughout the U.S. Radon can move up through the ground and into a home through cracks and holes in the foundation. Radon can build up to high levels in all types of homes. Radon can also get into indoor air when released from tap water from showering, washing dishes, and other household activities. Compared to radon entering the home through soil, radon entering the home through tap water will in most cases be a small source of radon in indoor air. Radon is a known human carcinogen. Breathing air containing radon can lead to lung cancer. Drinking water containing radon may also cause increased risk of stomach cancer. If you are concerned about radon in your home, test the air in your home. Testing is inexpensive and easy. Fix your home if the level of radon in your air is 4 picocuries per liter of air (pCi/L) or higher. There are simple ways to fix a radon problem that aren't too costly. For additional information, call your state radon program or call EPA's Radon Hotline (800-SOS-RADON).

Where does my water come from?

The Johnstown Water Treatment Plant treats water from three groundwater wells located adjacent to the plant on the grounds of the Belt Park on Jersey Street.

Quality Control Tests

Everyday a certified operator runs off a calibrations check on our online analyzers to make sure they are within range. The pH and free chlorine values are continuously monitored to keep a much tighter control on the water quality. This year we added a continuous analyzer for chlorine that samples every 2.5 minutes. Everyday the operator runs the following tests: pH, alkalinity, hardness, free chlorine, and total chlorine from the plant tap to make sure the water is of good quality. Also, everyday an operator gets a sample from around town to check for proper chlorine residuals. This year our tests included Nitrate, Total Trihalomethane, Haloacetic Acid, Nitrates, Volatile Organic Compounds, Inorganics, and arsenic. In all tests we were under EPA mandates and most were undetectable.

Well Susceptibility

Ohio EPA recently completed a study of the Village of Johnstown's source of drinking water, to identify potential contaminant sources and provide guidance on protecting the drinking water source. According to this study, the aquifer (water-rich zone) that supplies water to the Village of Johnstown has a low susceptibility to contamination. This determination is based on the following:

- Presence of thick protective layers of clay (total thickness approximately 130 feet) overlying the aquifer, providing significant protection from contamination movement between the ground surface and the aquifer,
- Significant depth (over 130 feet below the ground surface) of the aquifer,
- No evidence to suggest that ground water has been impacted by any significant levels of chemical contaminants from human activity, and
- Presence of significant potential contaminant sources in the protection area, which may further impact the Village of Johnstown's drinking water supply.

This susceptibility means that under existing conditions, the likelihood of the aquifer becoming contaminated is relatively low. This likelihood can be minimized by implementing appropriate protective measures. More information about the source water assessment or what consumers can do to help protect the aquifer is available by calling us at (740) 967-1139

Water System Contacts

Please Address Comments & Questions to:

Village of Johnstown
Division of Water & Wastewater
395 West Jersey Street
Johnstown, Ohio 43031

Visit us online at:

www.villageofjohnstown.org

Or email us at johnstownwtp@rrohio.com

For Comments or Questions about your water bill call the Utility Clerk's Office
(740) 967-5951

How to Get involved

For comments or questions regarding the plant process, tours, future system plans, or how to participate in decisions regarding your drinking water call Water Superintendent Jack Liggett at **(740) 967-4746**

Village Council Meets 1st and 3rd Tuesdays of the month at 7:30 pm at 599 South Main Street. For minutes and agendas, contact the Village Clerk at **(740) 967-3177**

Village of Johnstown Ohio

Division of Water and Wastewater 2008 Water Quality Report

Consumer Information for the Village of Johnstown Water System

Included in this Report:

- ⇒ Water Quality Data Table
- ⇒ General Health Information
- ⇒ Quality Control Tests
- ⇒ Water System Contacts
- ⇒ How to get involved

This consumer confidence report is an annual report required by EPA regulations and is designed to provide consumers of community water systems information on their drinking water.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants (Units)	MCLG	MCL	Level Found	Range of Detections	Violation	Sample Year	Typical Source of Contaminants
Inorganic Contaminants							
Fluoride (ppm)	4.0	4.0	0.58	0.58	No	2006	Water additive which promotes strong teeth; erosion of natural deposits.
Copper (ppm)	1.3	AL = 1.3	0.198	NA	No	2006	Corrosion of Household plumbing.
Zero out of twenty samples was found to have copper levels in excess of the copper action level of 1.3 ppm.							
Disinfection By-Products							
Total Trihalomethanes TTHMs (ppb)	0	80	27.7	27.7	No	2008	By-product of drinking water chlorination.
Haloacetic Acids HAA5 (ppb)	0	60	3.7	3.7	No	2008	By-product of drinking water chlorination.

Contaminants (Units)	MRDLG	MRDL	Level Found	Range of Detections	Violation	Sample Year	Typical Source of Contaminants
Residual Disinfectants							
Total Chlorine (ppm)	4	4	1.07	0.980- 1.43	No	2008	Water additive used to control microbes.

Units Description

Parts per Million (ppm), or Milligrams per Liter (mg/L): units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days.

Parts per Billion (ppb), or Micrograms per Liter (µg/L): units of measure for concentration of a contaminant. A part per billion corresponds to one second in a little over 31.7 years.

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

AL: Action Level: The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

MRDL: Maximum Residual Disinfection Limit: The maximum amount of a disinfection that may be present in the system at any given time.

MRDLG: Maximum Residual Disinfection Level Goal.

Total Trihalomethanes (TTHM): Sum of the concentrations of chloroform, bromdichloromethane, dibromochloromethane, and bromoform.

Haloacetic Acids (HAA5): Sum of the concentrations of mono-, di-, and trichloroacetic acids and mono- and dibromoacetic acids.

NA: Not applicable and or these compounds currently have no MCL and/or MCLG

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (A) **Microbial contaminants**, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. (B) **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming. (C) **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. (D) **Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also come from gas stations, urban stormwater runoff, and septic systems. (E) **Radioactive Contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.